

# INSULATION TESTER

Model : C362

## Features

- ◆ 4 Digits LCD Display
- ◆ Auto Range for all Functions
- ◆ 50 Segment Analog Display
- ◆ 0.01Ω for Low R Range
- ◆ 200GΩ for Insulation Measurement
- ◆ PC Interface with software
- ◆ Datalogger with 16,000 records
- ◆ Test Hold Function for Eazy Operation



## Specifications

- ◆ Button : Test, Lock, Hold, Zero, Rec, Backlight
- ◆ LCD Display : 4 digit
- ◆ AC Voltage



Range	Resolution	Accuracy
600V	0.1V	1.5%rdg + 3dpts

### ◆ DC Voltage

Range	Resolution	Accuracy
600V	0.1V	1%rdg + 3dpts

### ◆ Continuity beeper

Range	Protection
≤40Ω	600Vms

### ◆ Continuity


Range	Resolution	Accuracy
40 Ω	0.01Ω	1 % rdg+3dpts

### ◆ Resistance ( KR)

Range	Resolution	Accuracy
40 Ω to 4MΩ	0.1Ω to 1KΩ	1%rdg + 2dpts

### ◆ MΩ (Autoranging)

	Range	Resolution	Accuracy
250V	4M/40M/400M/20GΩ	1KW~2MΩ	2%rdg + 3dpts ≤ 10GΩ 3%rdg + 3dpts ≤ 20GΩ
500V	4M/40M/400M/100GΩ	1KΩ~10MΩ	2%rdg + 3dpts ≤ 10GΩ 3%rdg + 3dpts ≤ 20GΩ 10%rdg + 3dpts ≤ 200Ω
1000V	4M/40M/400M/200GΩ	1KΩ~20MΩ	2%rdg + 3dpts ≤ 10GΩ 3%rdg + 3dpts ≤ 20GΩ 10%rdg + 3dpts ≤ 200Ω



LED Backlight



PC Interface



**HTA INSTRUMENTATION (P) LTD.,**

An ISO 9001: 2015 Certified Company & NABL Accredited Calibration Laboratory as per ISO/IEC 17025:2017

Your One Stop For Instrumentation Supply, Automation & Calibration

# 73, Ramachandra Agrahara, Near T.R. Mills, Chamarajpet, Bangalore - 560018, INDIA.

Phone : 080-26749750, 26759253, 26740681 E-mail : sales@htaip.com Website : www.htaip.com



ISO 9001:2015 CERTIFIED  
Certificate No. IQSC202010014